

Installation Instructions for Economy Service Connector Blocks CB35S & CB35D

IMPORTANT

This product should be installed by a competent person and in accordance with the current IET Wiring Regulations. If in doubt, consult a qualified electrician.

INSTALLATION

Do not install or work on this product live.

Remove terminal block(s) from mounting box.

Remove knockouts appropriate for your installation and fix mounting box securely to a flat surface. Using single core cable BS 6004 type 6181Y of the correct current rating, 25mm² for 100A, connect cable(s) to the terminal block.

NOTE:

Only remove sufficient outer sheath for the cable to pass through the mounting box knockouts and remove sufficient inner insulation.

Securely tighten both terminal screws on each cable fitted.

Replace the lid and secure with one screw, this is sealable to prevent tampering.

Part No	Torque Setting
CB35S	2.5Nm Screw Size M6
CB35D	3.5Nm Screw Size M8

TECHNICAL INFORMATION

Rated voltage: 230V AC ~ 50Hz

Operating Temp: -10°C - +40°

Material: Black ABS Plastic

Conforms To: BS EN 60998-1
& BS EN 60998-2-1

GUARANTEE

Your GreenBrook Service Connector Block is guaranteed for 12 months from the date of purchase.

This does not affect your statutory rights.

Please keep these instructions for future reference.

INSTALLER

- Please pass instruction manual onto the owner of the unit